System Name: Sanbornville PWS ID: 2391010

2025 Report (2024 Data)

If a drinking water public notice, MCL, Monitoring/Reporting, or treatment technique violation has occurred, the following table should be used to explain the violation and health effects:

|               |                   |                   |                     | <b>VIOLATIONS</b>       |                                 |
|---------------|-------------------|-------------------|---------------------|-------------------------|---------------------------------|
| VIOLATIONS    | Date of violation | Explain violation | Length of violation | Action taken to resolve | Health Effects (Env-Dw 804-810) |
| Public notice | 7/6/2024          | OCCT              |                     | Addition of Ortho       | N/A                             |
|               |                   | Installation/Demo |                     | for corrosion           |                                 |
|               |                   |                   |                     | control and re-         |                                 |
|               |                   |                   |                     | sample                  |                                 |

<sup>\*</sup>The value must be reported as whole number, see Env-Dw 811, Appendix B for conversions. PLEASE note the units listed under the Contaminant Name.

## **LEAD AND COPPER**

| Contaminant<br>(Units) | Action<br>Level<br>(AL) | 90 <sup>th</sup> percentile sample value * | Date      | # of sites<br>above<br>AL | Violation<br>Yes/No | Likely Source of Contamination   | Health Effects of Contaminant  |
|------------------------|-------------------------|--|-----------|---------------------------|---------------------|--|--|
| Copper<br>(ppm)        | 1.3                     | 4.5  | 1/10/2024 |                           |                     | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives | Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.  |
| Lead<br>(ppb)          | 15                      | 0.014                                      | 1/10/24   |                           |                     | Corrosion of household plumbing systems, erosion of natural deposits                                   | (15 ppb in more than 5%) Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791).  (Above 15 ppb) Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. |

**Health Effects of Lead** Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.

\*If applicable report average, range, and date sampled if prior to the reporting year. Level detected must be reported as whole number, see Env-Dw 811, Appendix B for conversions. PLEASE note the units listed under the Contaminant Name.

|                        | DETECTED WATER QUALITY RESULTS |         |     |      |                     |  |  |  |  |  |  |
|------------------------|--------------------------------|---------|-----|------|---------------------|--|--|--|--|--|--|
| Inorganic Contaminants |                                |         |     |      |                     |  |  |  |  |  |  |
| Contaminant<br>(Units) | Level<br>Detected*             | Date    | MCL | MCLG | Violation<br>YES/NO | Likely Source of Contamination   | Health Effects of Contaminant  |  |  |  |  |
| Arsenic                | 0.0010<br>GPW 003              | 4/21/23 | 5   | 0    |                     | Erosion of natural<br>deposits; runoff from<br>orchards; runoff from<br>glass and electronics<br>production wastes | (2.5 ppb through 5 ppb) While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.  (Above 5 ppb) Some people who drink water containing arsenic in excess of |  |  |  |  |

|                                   |                                    |         |    |    |   | the MCL over many years could experience skin damage or problems with their circulatory system and may have an increased risk of getting cancer.  |
|-----------------------------------|------------------------------------|---------|----|----|---|---|
| Barium (ppm)                      | 0.0048<br>PH003<br>0.0047<br>PH002 | 4/21/23 | 2  | 2  | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits              | Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.  |
| Nitrate<br>(as Nitrogen)<br>(ppm) | GPW 003<br>1.2                     | 5/24/24 | 10 | 10 | Runoff from fertilizer<br>use; leaching from<br>septic tanks, sewage;<br>erosion of natural<br>deposits | (5 ppm through 10ppm) Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider. (Above 10 ppm) Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome. |

## **Volatile Organic Contaminants**

| Contaminant (Units)   | Level<br>Detected* | Date    | MCL | MCLG | Violation YES/NO | Likely Source of Contamination                  | Health Effects of Contaminant  |
|---|--------------------|---------|-----|------|------------------|---|--|
| Haloacetic Acids<br>(HAA)<br>(ppb)  | 2.7 RAA            | 7/19/24 | 60  | N/A  |                  | By-product of drinking water disinfection       | Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.   |
| Total Trihalomethanes (TTHM) (Bromodichloro- methane Bromoform Dibromochloro- methane Chloroform) (ppb) | 1.87 RAA           | 7/19/24 | 80  | N/A  |                  | By-product of<br>drinking water<br>chlorination | Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer. |

<sup>\*</sup>If applicable report average, range, and date sampled if prior to the reporting year. Level detected must be reported as whole number, see <a href="Env-Dw 811.25">Env-Dw 811.25</a> for conversion chart:

| PER- AND POLYFLUOROALKYL SUBSTANCES (PFAS) CONTAMINANTS |                    |      |     |      |                     |  |  |  |  |
|---|--------------------|------|-----|------|---------------------|--|--|--|--|
| Contaminant<br>(Units)                                  | Level<br>Detected* | Date | MCL | MCLG | Violation<br>YES/NO | Likely Source of Contamination   | Health Effects of Contaminant  |  |  |
| Perfluorohexane sulfonic acid (PFHxS) (ppt)             | ND                 |      | 18  | 0    |                     | Discharge from industrial processes, wastewater treatment, residuals from firefighting foam, | Some people who drink water containing perfluorohexane sulfonic acid (PFHxS) in excess of the MCL over many years could experience problems with their liver, endocrine system, or immune system, or |  |  |

| Perfluorononanoic acid (PFNA) (ppt)        | ND                              | 11 | 0 | runoff/leachate from landfills and septic systems  Discharge from industrial processes, wastewater treatment, residuals from firefighting foam, runoff/leachate from landfills and septic systems | may experience increased cholesterol levels. It may also lower a women's chance of getting pregnant.  Some people who drink water containing perfluorononanoic acid (PFNA) in excess of the MCL over many years could experience problems with their liver, endocrine system, or immune system, or may experience increased cholesterol levels.                          |
|--|---------------------------------|----|---|---|--|
| Perfluorooctane sulfonic acid (PFOS) (ppt) | 2.1 GPW 002<br>0.857 GPW<br>003 | 15 | 0 | Discharge from industrial processes, wastewater treatment, residuals from firefighting foam, runoff/leachate from landfills and septic systems  | Some people who drink water containing perfluorooctane sulfonic acid (PFOS) in excess of the MCL over many years could experience problems with their liver, endocrine system, or immune system, may experience increased cholesterol levels, and may have an increased risk of getting certain types of cancer. It may also lower a women's chance of getting pregnant. |
| Perfluorooctanoic acid (PFOA)<br>(ppt)     | GPW 002<br>3.5<br>.855<br>GPW3  | 12 | 0 | Discharge from industrial processes, wastewater treatment, residuals from firefighting foam, runoff/leachate from landfills and septic systems  | Some people who drink water containing perfluorooctanoic acid (PFOA) in excess of the MCL over many years could experience problems with their liver, endocrine system, or immune system, may experience increased cholesterol levels, and may have an increased risk of getting certain types of cancer. It may also lower a women's chance of getting pregnant.        |

|                          |                                      |         |                              |                              | SECONDARY CONTA                                  | AMINANTS                                    |   |
|--------------------------|--------------------------------------|---------|------------------------------|------------------------------|--|---|---|
| Secondary<br>MCLs (SMCL) | Level<br>Detected                    | Date    | Treatment technique (if any) | SMCL                         | 50 % AGQS (Ambient groundwater quality standard) | AGQS (Ambient groundwater quality standard) | Specific contaminant criteria and reason for monitoring |
| Chloride<br>(ppm)        | 46 GPW<br>003                        | 4/21/23 | N/A                          | 250                          | N/A  | N/A   | Wastewater, road salt, water softeners, corrosion       |
| рН                       | 6.47 GPW<br>003<br>6.52 GPW<br>002   | 4/21/23 | N/A                          | 6.5-8.5<br>(Normal<br>Range) | N/A  | N/A   | Precipitation and geology                               |
| Sodium (ppm)             | 28 GPW<br>003                        | 4/21/23 | N/A                          | 100-250                      | N/A  | N/A   | We are required to regularly sample for sodium          |
| Sulfate (ppm)            | 4.1 GPW<br>003                       | 4/21/23 | N/A                          | 250                          | 250  | 500   | Naturally occurring                                     |
| Zinc (ppm)               | 0.030 GPW<br>003<br>0.040 GPW<br>002 | 4/21/23 | N/A                          | 5                            | N/A  | N/A   | Galvanized pipes  |

|  | l . | l . |  |  |
|--|-----|-----|--|--|